

**RESOLUTION**

**WHEREAS**, an application has been submitted by the Borough of Riverdale for review by the Pequannock River Basin Regional Sewerage Authority (hereinafter the "Authority") of a Treatment Works Approval for construction of the Riverdale Phase 1 Sewer Project in the Borough of Riverdale, as more particularly described in the TWA application heretofore filed with the Authority and made a part hereof; and

**WHEREAS**, the project is for the construction of 8,355 linear feet of 8 inch diameter PVC gravity sewer to serve residential properties on all or part of Morris Avenue, Riverdale Parkway, Post Lane, Newberry Place, Brown Court, Loy Avenue, Oak Street, Cedar Street, Sonya Terrace and Cotliss Road, and would result in an increase of flow to the Authority System of 49,800 g.p.d.; and

**WHEREAS**, the Consulting Engineer of the Authority has reviewed the application and has determined said application to be in order; and

**WHEREAS**, the New Jersey Department of Environmental Protection (hereinafter the "NJDEP") presently requires the endorsement of the applicable Sewerage Agency pursuant to N.J.A.C. 7:14A-21 as to the proposed local sewer system extensions and its conformance with the Authority's Wastewater Management Plan, the Northeast Water Quality Management Plan and the Rules and Regulations of the Authority; and

**WHEREAS**, the Authority concurs in the findings set forth in the August 11, 2016 report of the Consulting Engineer on the application;

**NOW, THEREFORE, BE IT RESOLVED** by the Pequannock River Basin Regional Sewerage Authority in the Counties of Morris and Passaic and State of New Jersey, on this 21st day of September 2016, as follows:

1. The Chairman is authorized and directed to execute Form WQM-003 entitled "Statements of Consent" thereby signifying the approval of the Authority.

2. This approval is subject to the following conditions:

A. GENERAL CONDITIONS:

- 1) Receipt of a copy of the Resolution adopted by the Borough of Riverdale authorizing the filing of the application within 30 days of the date hereof.
- 2) Submission of a complying Level 1 Capacity Assurance calculation in accordance with Section 4.6 "Capacity Assurance Policy: Treatment Works Approval" of the Service Rules of the Pequannock River Basin Regional Sewerage Authority prior to execution of the Statement of Consent by the Chairman.

B. CONDITIONS PRECEDENT TO CONSTRUCTION:

- 1) Applicant must file with the Authority one copy of NJDEP Construction and Operating Permit (for TWA projects).
- 2) Applicant must provide 72 hours prior notice before beginning work.

C. CONDITIONS PRECEDENT TO OPERATION:

- 1) Applicant must file NJDEP WQM-005 form "Certification for Approval by Local Agency," with PRBRSA which form

must be executed (signed and sealed) by New Jersey licensed professional engineer and must be executed by the municipality which "will own and operate the sewer system."

- 2) Applicant must provide 72-hours prior notice prior to initiation of operations.
  - 3) Applicant must file two sets of record drawings signed and sealed by a New Jersey licensed professional engineer with PRBRSA.
  - 4) Applicant must file two sets of certified pressure and leakage testing results with PRBRSA.
3. This Resolution shall take effect as provided by law.

#### **CERTIFICATION**

Certified to be a true copy of a Resolution enacted at a duly convened public meeting of the Pequannock River Basin Regional Sewerage Authority held on September 21, 2016.



Edwin Howard, Secretary