

Resolution No. R-20-2-12

R E S O L U T I O N

WHEREAS, an application has been submitted by the Borough of Riverdale for review by the Pequannock River Basin Regional Sewerage Authority (hereinafter the "Authority") of a Treatment Works Approval for construction of the Riverdale Phase 4 Sewer Project in the Borough of Riverdale, as more particularly described in the TWA application heretofore filed with the Authority and made a part hereof; and

WHEREAS, the project is for the construction of 3,148 linear feet of 8-inch diameter PVC gravity sewer to serve an additional 63 residential single family (detached) properties within the Borough of Riverdale and would result in an increase of flow to the Authority System of 18,900 g.p.d.; and

WHEREAS, the Consulting Engineer of the Authority has reviewed the application and has determined said application to be in order; and

WHEREAS, the New Jersey Department of Environmental Protection (hereinafter the "NJDEP") presently requires the endorsement of the applicable Sewerage Agency pursuant to N.J.A.C. 7:14A-21 as to the proposed local sewer system extensions and its conformance with the Morris County Wastewater Management Plan, the Northeast Water Quality Management Plan and the Rules and Regulations of the Authority; and

WHEREAS, the Authority concurs in the findings set forth in the February 10, 2020 report of the Consulting Engineer on the application;

NOW, THEREFORE, BE IT RESOLVED by the Pequannock River Basin Regional Sewerage Authority in the Counties of Morris and Passaic and State of New Jersey, on this 19th day of February 2020, as follows:

1. The Chairman is authorized and directed to execute Form WQM-003 entitled "Statements of Consent" thereby signifying the approval of the Authority.

2. This approval is subject to the following conditions:

A. CONDITIONS PRECEDENT TO CONSTRUCTION:


- 1) Applicant must file with the Authority one copy of NJDEP Construction and Operating Permit (for TWA projects).
- 2) Applicant must provide 72 hours prior notice before beginning work.
- 3) Applicant must comply with the recommendations of the Consulting Engineer as set forth by his report of February 10, 2020 or as may be subsequently modified.

B. CONDITIONS PRECEDENT TO OPERATION:

- 1) Applicant must file NJDEP WQM-005 form "Certification for Approval by Local Agency," with PRBRSA which form must be executed (signed and sealed) by New Jersey licensed professional engineer and must be executed by the municipality which "will own and operate the sewer system."
- 2) Applicant must provide 72-hours prior notice prior to initiation of operations.
- 3) Applicant must file two sets of record drawings signed and sealed by a New Jersey licensed professional engineer with PRBRSA.

CERTIFICATION

Certified to be a true copy of a Resolution enacted at a duly convened public meeting of the Pequannock River Basin Regional Sewerage Authority held on February 19, 2020.


Edwin Howard, Secretary